

Результаты контрольных замеров электрических параметров
режимов работы ОАО "РСР" на 15.06.16. по городскому округу Подольск

питающий центр		№ ТП ОАО "РСР"	Нагрузка за летний режимный день, кВт	Напряжение, В			Ток, А		
№ ПС	№ фидера			А	В	С	А	В	С
1	2	3	4	5	6	7	8	9	10
ПС-319 РП-8,15	Ф.5	ТП-144	74,41	228	227	232	110	110	105
			0	221	220	220	0	0	0
		ТП-155	81,426	229	229	232	123	111	120
			111,902	230	232	229	158	150	178
		ТП-167	66,111	231	232	233	99	96	90
			99,97	226	227	229	162	152	126
		ТП-1617	59,089	229	228	230	85	83	90
			51,282	229	232	232	74	76	72
		ТП-137	32,575	227	227	230	62	43	38
		ТП-138	26,811	231	226	232	15	53	49
			1,636	236	238	232	0	2	5
		ТП-156	51,507	236	237	236	86	59	73
			54,205	236	236	235	99	56	75
		ТП-173	22,616	235	235	237	31	37	28
			21,105	233	240	234	27	12	51
		ТП-174	102,752	236	234	234	130	145	163
			137,701	236	235	234	196	185	205
		ТП-140	102,696	232	230	232	153	156	135
			31,788	230	230	231	36	54	48
		ТП-160	46,716	230	232	232	74	62	66
			73,434	220	237	240	153	102	65
		ТП-176	0						
		ТП-1607	4,942	243	214	215	0	3	20
	Итого	13	1254,674						
ПС-319	Ф.28,31	РТП-6	0						

		ТП-1716	5,946	220	222	220	15	3	9
		ТП-1661	51,935	235	235	235	76	60	85
		ТП-1713	3,152	225	229	223	12	1	1
	ИТОГО	4	61,033						
ПС-319 РП-10	Ф.7	ТП-1788	1,91	238	241	238	3	2	3
		ТП-1507	56,352	250	230	222	75	66	101
	ИТОГО	2	58,262						
ПС-319	Ф.2	ТП-409	219,23	220	219	220	363	330	305
	ИТОГО	1	219,23						
ПС-319 РП-32	Ф.3	ТП-1443	80,037	230	236	221	129	87	135
			0						
	ИТОГО	1	80,037						
ПС-319 РП-32	Ф.1,2	ТП-368	53,64	225	225	226	74	74	90
	ИТОГО	1	53,64						
ПС-319	Ф.12	ТП-4	140,735	235	230	237	172	194	235
	ИТОГО	1	140,735						
ИТОГО ПО	ПС-319	23	1867,611						
ПС-266 РП-43	Ф.16	ТП-1501	141,432	224	232	232	243	206	169
			0						
		ТП-1903	7,546	230	230	228	11	0	22
	ИТОГО	4	148,978						
ПС-266 РП-14	Ф.16	ТП-458	54,91	226	224	228	101	73	69
	ИТОГО	1	54,91						
ИТОГО ПО	ПС-319	5	203,888						
ПС-617 РП-4	Ф.1	ТП-1532	57,181	198	192	197	97	88	107
			0						
		ТП-1529	82,051	205	205	207	130	141	128
		ТП-1494	45,629	200	201	202	72	81	74
		ТП-1481	50,754	208	208	206	65	77	103

		ТП-1849	42,949	230	230	229	60	66	61
			0	222	223	221	0	0	0
		ТП-1593	30,322	237	229	233	46	38	46
		ТП-1626	6,31	209	210	212	8	13	9
		ТП-1597	51,438	201	206	213	116	60	74
	ИТОГО	8	366,634						
ПС-617	Ф.7	ТП-1849	42,949	230	230	229	60	66	61
РП-4			0	222	223	221	0	0	0
	ИТОГО	1	42,949						
ПС-617	Ф.6	ТП-1537	95,16	220	218	220	126	160	148
РП-4			0						
	ИТОГО	1	95,16						
ПС-617	Ф.3	ТП-1546	28,611	228	228	225	38	49	39
РП-4									
	ИТОГО	1	28,611						
РП-25		ТП-1877	13,779	238	238	237	15	18	25
			25,0315	238	237	237	28	34	43,5
		ТП-1967	18,587	238	237	240	38	19	21
			15,061	238	237	240	43	15	5,3
	ИТОГО	2	57,3975						
итого по	ПС-617	13	590,74						
ПС-182	Ф.11,12	ТП-367	40,476	232	232	230	60	53	62
		ТП-1489	67,259	223	223	224	85	80	136
	ИТОГО	3	107,735						
итого по	ПС-182	3	107,735						
ПС-596	Ф.12	ТП-1380	33,846	228	224	226	43	70	37
		ТП-1448	82,614	230	240	242	133	124	92
		ТП-1365	96,133	235	236	236	155	128	125
		ТП-1493	32,85	226	236	228	79	22	43
		ТП-1570	72,468	234	215	225	92	126	106
	ИТОГО	5	317,911						
итого по	ПС-596	5	317,911						

